

Performance Certificate



ENTIRE BAY OF PLENTY

Company:	Waipapa Tanks and Waste Treatment Systems Ltd
Address:	166 Waipapa Road RD 2 Kerikeri
Model Number:	Waipapa Tanks Nitro Treat® P-N 12-2
Description	Aerated submerged fixed film media
Manufacturer rated daily flow (litres)	2000 litres
Total operating capacity, including pump chamber (litres)	5872 litres
Primary tank (litres)	3500 litres

This is to certify that the **Waipapa Tanks Nitro Treat® P-N 12-2** wastewater treatment system supplied by **Waipapa Tanks and Waste Treatment Systems Ltd** is considered to meet the requirements of rule 13(f) of the Operative On-Site Effluent Treatment Regional Plan 2006. Therefore it may be installed throughout the Bay of Plenty, including the Rotorua Lakes' catchments as a permitted activity, provided that all other requirements of rule 12 or 13 of the regional plan are met.

This certificate relates only to the particular model described above, on the basis that the key specifications are the same as those in the model tested. This includes tank and chamber volumes, re-circulation rates, and textile/film total surface area.

For any questions about this certificate please contact Sam Weiss on 0800 368 267.

Note: 1 In order to comply with Regional Plan requirements (rule 13(o)) Environment Bay of Plenty must be provided with documentation for every advanced system, confirming that it has been installed to the manufacturer's specifications and that it fully meets the requirements of rule 13.

2 This performance certificate is based on the results from trial 1 (May 2005 – April 2006)

A handwritten signature in black ink, appearing to read 'S. Weiss'.

Sam Weiss
Project Implementation Officer
Environment Bay of Plenty

Expiry date: 1 November 2011